

District heating utilities of Veitur Utilities

Veitur's heating utilities with quantities of water produced, comments and improvements. Some actions were undertaken in West and South Iceland to ensure the operability of district heating utilities.

Numbers in table are rounded to the nearest thousand tons.

Utility	Production field	Number of wells	Annual production		Quantity	Comments	Improvements
			thous. tons	l/s			
Capital area							
	Laugarnes	10	5,171	164	Sufficient		
	Ellidaar	7	2,034	64	Sufficient		
	Reykir	22	16,351	518	Sufficient	Wholesale to Mosfellsbaer	
	Reykjahlid	12	14,688	466	Sufficient	Wholesale to Mosfellsbaer	
	Nesjavellir	18	26,899	853	Sufficient		
	Hellisheidi	31	12,201	387	Sufficient		
West Iceland							
HAB	Deildartunga hot spring	1	4,233	134	Limited		Further research to provide hot water to continue in 2020
	Wells in Baeir	2	321	10	Limited		
Skorradalur	Well in Stora Drageyri	1	295	9	Sufficient		
Munadarnes	Well iin Munadarnes	1	227	7	Sufficient		
Norðurardalur Utility	Well in Svartagil	3	368	12	Sufficient		
	Well at Bifrost	1	153	5	Sufficient		
Stykkisholmur	Wells in Stykkisholmur	2	774	25	Sufficient	One injection well and back-up power	
South Iceland							
Hveragerdi	Wells in Hveragerdi	2	38	1	Limited	Steam utility and closed-circuit systems	Work on improvements regarding the reservoir
Olfus	Bakki II	1	145	5	Sufficient		
Thorlakshofn	Bakki I	2	1,888	60	Sufficient		
Austurveita Utility	Wells in Gljufuraraholt	3	572	18	Sufficient	Most of the water used in Hveragerdi	
Grimsnæs Utility	Wells in Ondverðarnes	3	1,793	57	More than ample	Two wells in use	
Hlidarveita Utility	Wells at Efri-Reykir	1	665	21	Sufficient	The well provides water for two utilities	
	Wells at Kaldarholt	2	2,000	63	Sufficient		
Ranga Utility	Wells at Laugaland	2	1,137	36	Limited		Work on production capacity and prepare research to provide hot water