

Geothermal fluids discharged via overflows at the Hellisheidi Geothermal Power Plant and in Hverahlid

The reinjection utility is vulnerable to any operational changes and approximately 2% of produced geothermal water at Hellisheidi Power Plant was released via overflow. Licensors have been kept informed on the situation, on actions available at any given time and of the ongoing projects to increase the reception of the reinjection utility.

Date	Type of disturbance	24-hour average flow	Total m ³
Hellisheidi power plant			
January 14 th & 15 th	Malfunction	250	8,321
June 4 th – 7 th	Malfunction	70	24,000
August 26 th – October 11 th	Maintenance	230	777,000
Hverahlid			
November 12 th – 27 th	Malfunction	75	110,000